



City of Donald Public Works Department Annual Drinking Water Quality Report For Year Ended 12/31/2020



To protect the water system, a backflow prevention assembly (device that prevents the backflow of water) are required for all business and residential customers that present a potential hazard to the City's water system and are tested by the city once a year as required by the State. Donald is 100% backflow preventer Water System

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality of water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable

supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is two

deep wells located at: 10983 Rees Street, N.E. Both of these wells get their water from an underground aquifer. We are pleased to report that our drinking water is safe and meets all federal and state requirements.



Water Treatment Plant: 10983 Rees Street, Donald, Oregon 97020

The City of Donald's Mission Statement: To promote and improve our quality of life, while enhancing our sense of community, and preserving our small-town heritage for all.

Definitions

In the Test Results Table, as per EPA definitions, you will most likely find unfamiliar terms and abbreviations. To help you better understand these terms we've provided the following definitions.

Non-Detects (ND): Laboratory analysis indicates that the component is not present. *Unit of measurement.*

NTU (Nephelometric Turbidity Unit): The unit used to describe turbidity. Nephelometric refers to the way the instrument, a nephelometer, measures how much light is scattered by suspended particles in the water. The greater the scattering, the higher the turbidity. Therefore, low NTU values indicate high water clarity, while high NTU values indicate low water clarity. *Unit of measurement.*

Parts per million (ppm) or Milligrams per liter (mg/l): One part per million is like a single penny in \$10,000. *Unit of measurement.*

Parts per billion (ppb) or Micrograms per liter: One part per billion corresponds to a single penny in \$10,000,000. *Unit of measurement.*

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements a water system must follow.

Treatment Technique (TT): A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level Goal (MCLG): The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Contaminant Level (MCL): The maximum allowed is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible, using the best available treatment technology. MCL's are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.



Distribution System Flushing



Water Main Line Improvement and Service Connection for new business on Matthieu Street

Below: Mayor Olmsted, Council President Gonzalez, Councilors: Hellickson, Waller, McCracken, and Ostrander



All sources of drinking water are subject to potential contamination by substances that are naturally occurring or manmade. These substances can be microbes, inorganic or organic chemicals, and/or radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (1-800-426-4791).

Test Results Table

The City of Donald routinely monitors for elements and components in your drinking water according to federal and state laws. This table shows the results of our monitoring for the period of January 1 to December 31, 2020.

As you can see by the table, our system had no violations. We're proud that your drinking water meets or exceeds all federal and state requirements. We have learned through our monitoring and testing that some constituents have been detected. The Environmental Protection Agency (EPA) has determined that your water is safe at these levels. Thank you for allowing us to continue providing your family or business with clean quality water.

TEST RESULTS						
Contaminant	Violation	Level Detected in 2020	Unit	MCL	MCLG "GOAL"	Likely Source of Contamination
Microbiological Contaminants						
1. Total Coliform Bacteria	No	Zero monthly samples tested positive for total bacteria	ND	0	Presence of coliform bacteria in 5% max of monthly samples	These are naturally present in the environment and are used as an indicator that other, potentially harmful, bacteria may be present.
2. Fecal coliform and <i>E.coli</i>	No	Zero monthly samples tested positive for fecal coliform and <i>E.coli</i>	ND	0	A routine sample and repeat sample are total coliform positive, and one is also fecal coliform or <i>E. coli</i> positive	Fecal coliforms and <i>E. coli</i> are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, and/or other symptoms.
3. Turbidity	N/A	N/A	NTU	N/A	TT	Soil runoff
4. Arsenic	No	0.0047 Well #2 & #1	PPM	0.010	0	Erosion of natural deposits, run off from orchards, run off from glass and/or electronic production wastes.
5. Nitrate (as N)	No	0.003: Well #2 & #1	PPM	10	10	Run off from fertilizer use, leaching from septic tanks, sewage, and/or erosion of natural deposits.
6. Lead	No	0.0050	PPM	AL= 0.0155	0	Corrosion of household plumbing systems, and/or erosion of natural deposits.
7. Copper	No	0.1100	PPM	AL= 1.35	1.3	Corrosion of household plumbing systems; erosion of natural deposits, leaching from wood preservatives.

A special note for the immune deficient: Some people may be more vulnerable to contaminants in drinking water than the general population. Immune-compromised persons, such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. People who fall into these previous groups, should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection, by cryptosporidium and other microbiological contaminants, are available from the Safe Drinking Water Hotline (1-800-426-4791).



For questions about information contained in this report please contact:

Public Works Director
Alonso Limones

PHONE: 503-678-1411

EMAIL:
publicworks@donaldoregon.gov

Public Works Hours:
Monday- Friday
7:00 A.M. to 3:00 P.M.

Public Works Emergency
Pager Number:
Available 24 hours a day,
7 days a week
503-301-6479

City Manager
Heidi Bell

PHONE: 503-678-5543

EMAIL:
manager@donaldoregon.gov

City Hall:
10710 Main Street
P.O. Box 388
Donald, OR 97020

City Hall Hours:
Monday-Thursday
8:00 A.M. to 4:00 P.M.
Fridays:
8:00 A.M. to 12:00 P.M.

Visit the City's webpage at:
www.donaldoregon.gov

Sign up for Emergency and Event
Notifications at FlashAlert.net

About Our Organization...

The City of Donald Public Work's staff works around the clock to provide top quality water for every tap. We ask that all our customers help us protect the water sources, which are the heart of our community, our way of life, and our children's future. We want our valued customers to be informed about their water utility. If you have any questions about this report or concerning your water, please contact the City of Donald Public Works Department at: 503-678-1411 or Donald City Hall at: 503-678-5543. If you want to learn more, please attend a City Council meeting. They are held at City Hall on the second Tuesday of the month at 6:45 P.M.

Ways You Can Help Protect and Conserve Our Water System

- ✓ Pick up dog and pet waste, and throw it away in the trash.
- ✓ Recycle and dispose properly of cooking oils, motor oil, paints, detergents, pesticides, household hazardous materials, household batteries and medications. These can be dropped off at recycling centers, and check the availability with *Loren's Sanitation* for curbside recycling opportunities. Call: 503-393-2262.
- ✓ Conserve your water use!
 - Turn off the water while you brush your teeth.
 - Make sure your taps and toilets are leak free.
 - Shorten your shower time.
 - Don't forget to water your lawn and plants wisely.
 - Run only full loads of laundry or dishes.

Thank you for your help!